



FREDERICK COUNTY GOVERNMENT

Jan H. Gardner
County Executive

DIVISION OF FINANCE

Department of Procurement & Contracting

Lori L. Depies, CPA, Division Director

Diane Fouche, CPPB, Director

October 1, 2018

Request for Proposal #18-410, Water Storage Tank Improvements Addendum #2

This Addendum contains revisions, clarifications, and information pertinent to the title solicitation and shall supplement, amend, and become part of the solicitation. All responses shall be based upon the information provided in this Addendum, in accordance with the solicitation documents.

Acknowledgment of this Addendum shall be submitted with the response, including addendum number and date. Failure to acknowledge addenda may subject the Contractor to disqualification.

Proposals are due October 17, 2018 before 3:00 PM.

QUESTIONS:

- 1. Question:** *East County Tank: Does the County have existing spare conduit to run power to the tank for the THM control panel or are we required to trench from the power supply to the tank?*

Answer: There is one spare conduit in the bank shown on the drawings provided that is available. It is 1-inch PVC.

- 2. Question:** *Can you please advise how Frederick (County) takes their samples for THMs and where samples are taken from?*

Answer: Samples are taken at MDE approved locations in the distribution system, by certified water collectors using EPA Method 524.2. At the East County Tank there are sampling taps before and after the tank. There are not sampling taps at the Pontius Tank site at this time. The County recognizes the need to sample the system in order verify THM removal. Therefore, additional sampling points will be considered by the County.

Except as noted herein, all terms and conditions of the document referenced, as heretofore changed, remain unchanged and in full force and effect.

Brian Stieg, Project Manager IV
Department of Procurement & Contracting